

CITY OF VINELAND
DEPARTMENTAL REQUEST FOR PUBLIC BIDDING

1. NATURE OF REQUEST: EMS Billing Services

2. ENGINEER'S ESTIMATE: \$ 5.95% of revenue recovered
(If Engineer's Estimate has been prepared by anyone other than the person signing this form, please attach a copy of said Engineer's Estimate.)

3. AMOUNT BUDGETED FOR THIS REQUESTED ITEM: \$ 5.95% of revenue recovered requested

4. BUDGETED ITEM: YES NO
(If no, is it an ordinance authorized material, service or supply?)
YES NO ORDINANCE NO.: _____

(B) Please identify the page number and line item appropriation sub-account:

Budget Page No. pending Account No. 001-0-29-35-3503-1-5023038

5. Check here if:
Federal Funds State Funds
UEZ Funds Davis Bacon Requirements

(If any of the above are checked, the project must be monitored by the department for compliance with prevailing wage rate policy and procedures.)

6. Date to be Advertised: August 25, 2015

7. Date to be Received: September 22, 2015

8. Date to be Awarded: October 27, 2015

9. Special Conditions or Instructions: _____

10. The following must be attached:

- Summary of Project
- Specifications
- Plans (if applicable)
- Bidders Mailing List (with emails of the vendor)

11. Specifications Prepared by: Alfred Lincks, EMS Chief, 6185
(NAME, TITLE AND EXTENSION NUMBER)

12. Approved by: *Dave Jones* 8/3/15
SIGNATURE (DIRECTOR, DEPARTMENT HEAD, SUPERVISOR)


Send copies to:
Purchasing Department
Business Administration

CITY OF VINELAND
DEPARTMENTAL REQUEST FOR PUBLIC BIDDING

1. NATURE OF REQUEST: Insertion Valve Equipment

2. ENGINEER'S ESTIMATE: \$ 55,000.
(If Engineer's Estimate has been prepared by anyone other than the person signing this form, please attach a copy of said Engineer's Estimate.)

3. AMOUNT BUDGETED FOR THIS REQUESTED ITEM: \$ 55,000.00



4. BUDGETED ITEM: YES NO
(If no, is it an ordinance authorized material, service or supply?)

YES NO ORDINANCE NO.: 2014-46

(B) Please identify the page number and line item appropriation sub-account:

Budget Page No. n/a Account No. n/a

5. Check here if:

Federal Funds State Funds
UEZ Funds Davis Bacon Requirements

(If any of the above are checked, the project must be monitored by the department for compliance with prevailing wage rate policy and procedures.)

6. Date to be Advertised: 8/25/15

7. Date to be Received: 9/22/15

8. Date to be Awarded: 10/20/15

9. Special Conditions or Instructions: na

10. The following must be attached:

Summary of Project
Specifications
Plans (if applicable)
Bidders Mailing List (with emails of the vendor)

11. Specifications Prepared by: Michael Lawler 4755
(NAME, TITLE AND EXTENSION NUMBER)

12. Approved by: [Signature]
SIGNATURE (DIRECTOR, DEPARTMENT HEAD, SUPERVISOR)

Send copies to:
Purchasing Department
Business Administration

[Handwritten mark]

SPECIFICATIONS

VALVE INSERTION SYSTEM

PART 1 - GENERAL

1.01 DESCRIPTION

The Equipment provided shall be capable of installation, without shutdown, at one location, of pipe sizes, in the range of 4" to 12" diameters. The capabilities specified herein are minimum mandatory requirements that must be met by any Insertion Equipment or Insertion Valve offered.

1.02 SCOPE OF WORK

The work of this section shall include the furnishing, installation, and testing of all insertion valves and appurtenant equipment as specified herein and as required to make the facility operable and complete. The system shall provide a means to install a permanent block (open-close) valve into a pressurized pipe, with no interruption of flow through the pipe and no reduction of line pressure. The valve insertion shall be accomplished through a single circular hole cut (under full line pressure) into the top of the pipe. The system shall permanently remain in the piping to allow for shutdowns in the same manner as any typical gate, ball or butterfly block valve.

Items to be provided include, but shall not be limited to the following:

- A. Insertion Valves Material as to AWWA C509-09, et. seq.
- B. Insertion Valve Installation Equipment complete

CITY OF VINELAND
DEPARTMENTAL REQUEST FOR PUBLIC BIDDING

1. NATURE OF REQUEST: Open Ended Specification for Services - Locating & Marking of URD Electric Facilities

2. ENGINEER'S ESTIMATE: \$ 78,000
(If Engineer's Estimate has been prepared by anyone other than the person signing this form, please attach a copy of said Engineer's Estimate.)

3. AMOUNT BUDGETED FOR THIS REQUESTED ITEM: \$ 78,000

4. BUDGETED ITEM: YES NO
(If no, is it an ordinance authorized material, service or supply?)

YES NO ORDINANCE NO.: _____

(B) Please identify the page number and line item appropriation sub-account:

Budget Page No. _____ Account No. 002-0-54-90-9003-2-7023393

5. Check here if:

Federal Funds State Funds

UEZ Funds Davis Bacon Requirements

(If any of the above are checked, the project must be monitored by the department for compliance with prevailing wage rate policy and procedures.)

6. Date to be Advertised: 08/25/2015

7. Date to be Received: 09/22/2015

8. Date to be Awarded: 10/13/2015

9. Special Conditions or Instructions: _____

10. The following must be attached:

Summary of Project

Specifications

Plans (if applicable)


Bidders Mailing List (with emails of the vendor)

11. Specifications Prepared by: Dexter L. Gordon; Principal Engineer; #4276
(NAME, TITLE AND EXTENSION NUMBER)

12. Approved by:

[Signature]
SIGNATURE (DIRECTOR, DEPARTMENT HEAD, SUPERVISOR)

Send copies to:
Purchasing Department
Business Administration



*Deed 08/27/15
Request to Permit
8/27/15*



August 5, 2015

Summary of Project
Open Ended Specification for
Locating & Marking of
Underground Electric Facilities

To: Council Members

From: Dexter L. Gordon, Principal Engineer

A handwritten signature in black ink, appearing to read 'D. Gordon', is written over the text 'Principal Engineer'.

This specification shall cover the furnishing and delivery of services for Locating and Marking of Underground Electric Facilities maintained by and belonging to City of Vineland Municipal Electric Utility for the period of 12 months. Also included as part of this specification is an "option" for a second year.