CITY OF VINELAND, NJ

RESOLUTION NO. 2016-____

A RESOLUTION AWARDING A CONTRACT TO TDI, NABB, IN FOR SURPLUS TRANSFORMER AND ELECTRICAL EQUIPMENT SALVAGE AND DISPOSAL FOR THE VINELAND MUNICIPAL ELECTRIC UTILITY – DISTRIBUTION DIVISION.

WHEREAS, the City of Vineland has heretofore advertised for bids for Surplus Transformer and Electrical Equipment Salvage and Disposal for the Vineland Municipal Electric Utility - Distribution Division, in accordance with specifications on file in the office of the Purchasing Agent; and

WHEREAS, on March 22, 2016, bids were received, duly opened and read aloud, being referred to the Assistant Business Administrator for tabulation, evaluation, report and recommendation; and

WHEREAS, the Assistant Business Administrator has, under date of April 19, 2016 submitted a written report and tabulation of the bids received and has recommended that a contract for Surplus Transformer and Electrical Equipment Salvage and Disposal for the Vineland Municipal Electric Utility - Distribution Division, be awarded to TDI, Nabb, IN as follows:

Credits to VMU \$/lb for Pole Type Units Less Than 50PPM & Padmount Units Less than 50PPM	\$.08/lb
Charge to VMU \$/lb for equip. disposal 50-499PPM	\$.40/lb
Charge to VMU \$/lb for equipment disposal over 500PPM	\$1.00/lb
In the estimated amount not to exceed	\$16,500.00

said bid being the lowest evaluated bid received and considered in the best interest of the City of Vineland; now, therefore,

BE IT RESOLVED by the Council of the City of Vineland that said contract for Surplus Transformer and Electrical Equipment Salvage and Disposal for the Vineland Municipal Electric Utility - Distribution Division, be and the same is awarded to TDI, Nabb, IN, on their bid as stated above, said bid being the lowest evaluated bid received and considered in the best interest of the City of Vineland, and the Purchasing Agent be and the same is hereby authorized and directed to issue purchase order contract for the same in behalf of the City; and

BE IT FURTHER RESOLVED that the City Comptroller has certified that the funds for the contract to be awarded herein are available.

Adopted:	
ATTEST:	President of Council
City Clerk	



April 19, 2016

REPORT TO: THE MAYOR AND COUNCIL

RE: Proposals Submitted to the Purchasing Board 3/22/16

Dear Mayor and Members of Council:

Submitted to you herewith for your consideration is our evaluation of the proposals submitted to the Purchasing Board on March 22, 2016.

SURPLUS TRANSFOMER AND ELECTRICAL EQUIPMENT SALVAGE AND DISPOSAL FOR THE VINELAND MUNICIPAL ELECTRIC UTILITY – DISTRIBUTION DIVISION

It is the recommendation of the Director of Municipal Utilities, which has the concurrence of the Purchasing Agent and Assistant Business Administrator that a contract be awarded to the lowest evaluated bidder, TDI, Nabb, IN as follows:

Credits to VMU \$/lb for Pole Type Units Less Than 50PPM & Padmount Units Less than 50PPM

\$.08/lb

Charge to VMU \$/lb for equip. disposal 50-499PPM

\$.40/lb

Charge to VMU \$/lb for equipment disposal over 500PPM \$1.00/lb

In the estimated amount not to exceed

\$16,500.00

We trust that the above recommendation will receive your favorable consideration and that the recommended resolution will be adopted as presented.

Respectfully submitted,

Robert E. Dickenson, Jr.

Assistant Business Administrator

RD/wr



BID EVALUATION FORM

DEPARTMENT ELECTRIC UTILITY DEPARTMENT

Date: 3-23-2016 The undersigned recommends that a contract be awarded for the following: 1. Bid Title: TRANSFORMER & ELECTRICAL EQUIP. DISPOSAL 2. Amount to be Awarded: 16,500 **✓** Encumber Total Award Encumber by Supplemental Release 3. Engineer's Estimate: Zero 4. Amount Budget: \$ Zero 5. Account Number to be Charged: E595 022-0-54-90-9003-2-702.3437 6. Date Bids Received: 03.22.2016 7. Date to be Awarded: 04.12.2016 8. Recommended Vendor: TDI, Nabb, IN 9. Is Recommended Vendor the Apparent Lowest Bidder? ✓ Yes No Attached -10. Comments/Special Instructions: 11. Evaluation Performed by: John Boyle 12. Approved By:

13. Attached: (Check-Off List)

✓ Tabulation of Bids

Justification for Vendor Recommendation (if applicable)

✓ Evaluation Data (if applicable)

Send copies to:

Purchasing Division Business Administration





Transformer & Electrical Equipment Salvage and Disposal March 23, 2016

Whereas, the NJDEP and the Federal EPA require that all oil filled electrical equipment be decommissioned and salvaged or disposed of in accordance with federal regulations in a timely manner, VMU has solicited quotations from licensed vendors to pick up, manifest, transport and either salvage or dispose equipment from our facility at Second and Peach Street.

Over the past two decades, the salvage value has equaled or exceeded the disposal costs. However, this year, with commodity pricing down and the handling and disposal costs increasing, the costs to remove this equipment from our facility and to document and dispose may exceed the actual salvage value.

Unfortunately, the environmental regulations preclude us from storing the equipment on site to await a more favorable commodities market. We have no other recourse than to award this contract to the best evaluated bid and proceed with having the equipment removed from our premises and disposed of in accordance with the environmental regulations.

Therefore, I recommend the award of this contract to TDI, 3478 W Marble Hill Rd, Nabb, IN., the estimated amount Not to Exceed \$16,500.00.

Prepared By:

7 23 2018

John Boyle, Asst. G.M. Municipal Utilities

Transformer Salvage Disposal March 22nd, 2016

CREDIT Less then 50PPM OH Xfmr CREDIT Less then 50PPM UG Xfmr	90000 30000	TCI NY Unit Price 0.00 0.00	TCI NY Calculated Bid 0.00 0.00	EPS WV Unit Price 0.00 0.00	EPS WV Calculated Bid 0.00 0.00	TDI IN Unit Price 0.08 0.08	TDI IN Calculated Bid 7,200.00 2,400.00	SOLOMON, TN Unit Price 0.04 0.01	SOLOMON, TN Calculated Bid 3,600.00 150.00
Charg: Non-PCB Capacitor	1000	0.50	500.00	1.00	1,000.00	0.35	350.00	0.50	500.00
Charg: 50-499PPM	25000	0.00	0.00	0.27	6,750.00	0.27	6,750.00	0.50	12,500.00
Charg: Over 500PPM	10000	0.75	7,500.00	0.65	6,500.00	1.00	10,000.00	1.00	10,000.00
Charg: PCB Test (Non-Stickered Units)	50	25.00	1,250.00	20.00	1,000.00	15.00	750.00	0.00	0.00
Freight Charge	4	2,100.00	8,400.00	1,925.00	7,700.00	2,000.00	8,000.00	0.00	0.00
		TOTAL:	(17,650.00)		(22,950.00)		(16,250.00)		(19,250.00)


^{*} REQ's VMU to Sample all units.


EST Charge \$25.00

Typical 17.5 #/kva

^{**} Quoted per kva

TABULATION OF BIDS SURPLUS TRANSFORMER & ELECTRICAL EQUIPMENT SALVAGE & DISPOSAL





	TCI OF NY LLC 99 Coeymans Ind. Pk. Lane Coeymans, NY	Environmental Protection Services 4 Industrial Pk Drive Wheeling, WV	TDI 3478 W. Marble Hill Rd. Nabb, IN	Solomon Corporation 201 Polymer Dr. PO Box 1009 Decatur, TN
Credits to VMU \$/lb for Pole Type Units Less Than 50PPM &	NO CHARGE/ LB	No charge/ No Credit/lb	\$.08/1b	\$.10/ KVA **
Padmount Units Less than 50PPM Charge to VMU \$/lb for equip. disposal 50-499PPM	NO CHARGE/LB	\$.27/lb	\$.40/lb	\$.50/lb
Charge to VMU \$/lb for equip. disposal over 500PPM	\$.75/LB *	\$.65/lb	\$1.00/lb	\$1.00/lb

*NON PCB CAPS- \$.50/LB;

PCB CAPS-\$2.30/LB

** Also bid Credits to VMU \$/KVA to Pole Type Units Less than 50PPM @ \$.75/KVA

Specifications Also Sent To:

Utility Transformer Brokers Transformer Salvage Inc. Veolia North America

Summary of Project: Vld. Mun. Ele. Dept. is seeking proposals for the pickup, manifesting, transportation, testing, salvage &/or disposal of oil filled dist. Transformers, & documentation of destruction. Bidders must be EPA licensed under 40CFR Part 761.

